

**Horse Heaven Wind Project EFSEC Review  
Data Request No. 2 (received July 16, 2021) – Supplemental Response Package No. 3 (November 2, 2021)**

The following contains Scout’s supplemental response to EFSEC’s data request Vegetation-7. Both the original response provided to EFSEC on 8/16/2021 as well as the new supplemental response is provided for this data request.

Data Request 2 Item ID	Code Citation Application Section	Item	Question or Information Request.	Applicant Response <i>(bold text indicates response conclusion and Applicant commitments, including commitments to provide supplemental materials)</i>
Vegetation-7	WAC: 463-60-332  Section 3.4.2	Potentially Hazardous Substances Storage and Protection of Vegetation and Wildlife	Identify all potentially hazardous substances that will be stored or used in the construction or operation of the Project, even in low quantities (lubricating oils and hydraulic fluid are the only ones mentioned in reference to “small quantities of a few hazardous materials may be used or stored” Section 2.10.1).  Include required minimum spill kit contents for equipment on-site and the temporary fuel storage facilities.	<p><u>--Original Response:</u>  <b>A detailed construction spill prevention plan will be developed by the Balance of Plant Contractor and submitted to EFSEC for review prior to construction. Measures to prevent and contain any accidental spills will be listed in the project-specific Spill Prevention, Control, and Countermeasures (SPCC) Plan. The following provides information regarding the potentially hazardous substances that may be stored or used in the construction or operation of the Project:</b></p> <ul style="list-style-type: none"> <li>• Small quantity of potentially hazardous substances: <ul style="list-style-type: none"> <li>• Synthetic Lubricating Oil</li> <li>• Glycol-water mix</li> <li>• Transformer Mineral Oil</li> <li>• Hydraulic fluid (if Turbine equipment requires it)</li> </ul> </li> <li>• Other potentially hazardous substances: <ul style="list-style-type: none"> <li>• Diesel fuel</li> </ul> </li> </ul> <p><u>--New Supplemental Response:</u>  <b>A detailed construction spill prevention plan will be developed by the Balance of Plant Contractor and submitted to EFSEC for review prior to construction. Measures to prevent and contain any accidental spills will be listed in the project-specific Spill Prevention, Control, and Countermeasures (SPCC) Plan. The following provides information regarding the potentially hazardous substances that may be stored or used in the construction or operation of the Project:</b></p> <ul style="list-style-type: none"> <li>• Small quantity of potentially hazardous substances: <ul style="list-style-type: none"> <li>• Synthetic Lubricating Oil</li> <li>• Glycol-water mix</li> <li>• Transformer Mineral Oil</li> <li>• Hydraulic fluid (if Turbine equipment requires it)</li> </ul> </li> <li>• Other potentially hazardous substances: <ul style="list-style-type: none"> <li>• Diesel fuel</li> </ul> </li> </ul> <p><b>The contents of the various spill kits that will be stored at permanent and temporary on-site project facilities varies; however, a typical spill kit will contain the following:</b></p> <ul style="list-style-type: none"> <li>• 55-gallon disposable barrels (note that the exact volume of the barrels will be relative to the volume needed at the targeted site/location)</li> <li>• Oil Absorbent Pads, Pillows, and Socks (the exact number of each item per kit varies, but a typical kit will have approximately 100 pads, 4 pillows, and 4 socks)</li> <li>• Disposal Bags,</li> <li>• Goggles and Nitrile Gloves</li> <li>• Spill Kit Instructional Handbook</li> </ul>